

भारत सरकार
केंद्रीय विद्युत प्राधिकरण
सेवा भवन (उत्तरी खंड) कक्ष सं. 622, छठा तल,
आर.के.पुरम, नई दिल्ली-110066
टेलीफ़ोन – 011-26732632, ई-मेल – celegal-cea@gov.in
वेबसाइट – www.cea.nic.in

सार्वजनिक नोटिस

केंद्रीय विद्युत प्राधिकरण (के.वि.प्रा.), विद्युत अधिनियम, 2003 की धारा 177 के तहत प्रदत्त शक्तियों का प्रयोग करते हुए, केंद्रीय विद्युत प्राधिकरण (मीटरों की स्थापना और संचालन) संशोधन विनियमों, 2026 के प्रारूप को अधिसूचित करने का प्रस्ताव करता है। हितधारकों से टिप्पणी हेतु विनियमों का उक्त प्रारूप के.वि.प्रा. की वेबसाइट www.cea.nic.in पर उपलब्ध हैं।

2. सभी हितधारकों एवं आम जनता से प्रारूप विनियमों पर अपनी टिप्पणियां ई-मेल (celegal-cea@gov.in) अथवा डाक के जरिए मुख्य अभियंता (विधि), कमरा नं. 622, सेवा भवन, (उत्तरी खंड), 6वां तल, आर.के.पुरम, नई दिल्ली-110066 को 26 मार्च, 2026 तक भेजने का अनुरोध किया जाता है।

(राकेश कुमार)
सचिव, के.वि.प्रा.

[To be published in the Gazette of India, Extraordinary, Part III, Section 4]

GOVERNMENT OF INDIA
MINISTRY OF POWER
CENTRAL ELECTRICITY AUTHORITY
NOTIFICATION

New Delhi, the.....,2026

F No.1/12/CEA/DPM/Regulations/2025 —Whereas the draft regulations proposing to amend the Central Electricity Authority (Installation and Operation of Meters) Regulations, 2006, was published in six newspaper dailies, as required by sub-section (3) of section 177 of the Electricity Act, 2003 (36 of 2003) read with sub-rule (2) of rule 3 of the Electricity (Procedure for Previous Publication) Rules, 2005, for inviting objections and suggestions from all persons likely to be affected thereby, before the expiry of the period of thirty days, from the date on which the copies of the newspaper containing the said draft regulations was made available to the public;

And whereas copies of the said newspapers containing the said draft regulations was made available to the public on the website of the Central Electricity Authority on the 23rd February, 2026;

And whereas the objections and suggestions received from the public on the said draft regulations were considered by the Central Electricity Authority;

Now, therefore, in exercise of the powers conferred by clause (c) of sub-section (2) of section 177 read with sub-section (1) of section 55 of the Electricity Act, 2003(36 of 2003), the Central Electricity Authority hereby makes the following regulations further to amend the Central Electricity Authority (Installation and Operation of Meters) Regulations, 2006, namely: –

1. Short Title and Commencement. -(1) These regulations may be called the Central Electricity Authority (Installation and Operation of Meters) Amendment Regulations, 2026.
(2) They shall come into force on the date of their publication in the Official Gazette.
2. In the Central Electricity Authority (Installation and Operation of Meters) Regulations, 2006 (herein after referred to as the said regulations), in sub-regulation (1) of regulation 4, for clause (b) the following shall be substituted, namely:-

“(b) All consumers in areas with communication network, shall be supplied electricity with Smart Meters conforming to relevant IS, within the timelines as provided by the Central Government:

Provided that all consumer connections having current carrying capacity beyond that specified in relevant IS, shall be provided with meters having automatic remote meter reading facility or Smart Meters as per relevant IS:

Provided further that in areas which do not covered with communication network, installation of prepayment meters, conforming to relevant IS, shall be allowed by the respective State Electricity Regulatory Commission.

Provided also that all the Advanced Metering Infrastructure shall include the prepayment functionality and shall be interoperable in accordance with the guidelines issued by the Authority:

Provided also that the Smart Meter conforming to relevant Indian Standard with accuracy class of 1.0/0.5S shall act as an Interface meter for the consumer permitted open access at voltage level not exceeding 650 V.”.

3. In regulation 7 of the said regulations, in sub-regulation (1), in clause (a), in Table-1 for Sl. No. 4 and the entries relating thereto, the following Sl. Nos. and entries relating thereto shall be substituted, namely: -

| Sl. No. | Stages | Main Meter | Check Meter | Standby Meter |
|---------|--|----------------------|----------------------|---|
| (1) | (2) | (3) | (4) | (5) |
| “4. | Consumer directly connected to the Inter-State Transmission System or Intra-State Transmission System or Distribution System who has been permitted open access at voltage level exceeding 650 V by the Appropriate Commission or any other system not covered above | At consumer premises | | At consumer premises on separate Instrument Transformer or at Licensee’s substation as mutually agreed. |
| 5. | Consumer permitted open access at voltage level not exceeding 650 V | At consumer premises | At consumer premises | -----”. |

Rakesh Kumar, Secretary
Central Electricity Authority

Note: The principal regulations were published in the Gazette of India, Extraordinary, Part III, Section 4, *vide* notification No. 502/70/CEA/DP&D, dated the 22nd March, 2006 and last amended *vide* notification No. CEA-GO-13-15(12)/1/2022-DPR Division, dated the 28th February, 2022.